



Sweetwater Environmental Management, LLC

720 East Landis Avenue, Rear
Vineland, New Jersey 08360

School Potable Water System Lead Testing

**Township of Franklin Public Schools
Administration Building
3223 Coles Mill Road
Franklinville, NJ 08322**

07/31/2017

Prepared By:
Frederick J. Gross, REM • CEA • LO
Sweetwater Environmental Management, LLC

Drinking Water Outlet Inventory & Results

Name of School: Board of Education Address: 3228 Coles Mill Road, Franklinville, NJ 08322

Date Completed: 7-12-2017

#	Outlet Type	Location	Code	Lead Result ug/l	Lead Limit ug/l	Map ID	Comments
1	Sink	Staff Room	BOE-RM21-KC-01	<1	15	01	SAMPLE, Incompliance
2	Water Cooler	Hall	BOE-MHCT-WC-01	<1	15	02	SAMPLE, Incompliance
3	Sink	Women's Room	BOE-RM10-BS-03	N/A	N/A	03	Non-Drinking Water Outlet, No Sample
4	Sink	Men's Room	BOE-RM07-BS-04	N/A	N/A	04	Non-Drinking Water Outlet, No Sample
5	Sink	Superintendent's Rest Room	BOE-BM03-BS-05	N/A	N/A	05	Non-Drinking Water Outlet, No Sample

* ug/l = Micrograms per Liter or Parts per Billion

TABLE KEY

	Sample collected, the result was less than the LEAD Action Limit (15 ug/l), sample is acceptable for potable water.
	Sample collected, the result was greater than the LEAD Action Limit (15 ug/l), outlet was removed and plumbing sealed.
N/A	NO Sample collected, outlet exempted, NOT A DRINKING WATER SOURCE, sanitation only hand wash or equipment sink

